



May 4, 2022

Re: Low Water Cutoff

Product: MAC, MAH, MACF and MAHF series Boilers

The MAC/F and MAH/F series boilers incorporate a CSA approved Low Water cutoff device. This low water device is a pressure sensing switch. If the system starts to lose water the pressure will drop and the sensor will stop the boiler before the point of unsafe operation. This will result in a low water error code which cannot be reset until the system has regained proper water pressure.

If you require additional information feel free to contact your Utica rep or Technical Support.

Sincerely,

A handwritten signature in black ink that reads "Don DeCarr".

Don DeCarr
Manager - Quality & Aftermarket Support